

Example Plumbing

BACKFLOW TEST REPORT

DEMO-003

PASSED

Example Plumbing

100 Example Street
Kansas City, MO 64105
(816) 555-0100

TEST DATE Sep 21, 2026
REASON Annual test
TESTER Example plumber

PREPARED FOR

Example Property Group

300 Example Boulevard
Kansas City, MO 64108

SERVICE AT

Example office building

300 Example Boulevard
Kansas City, MO 64108

Test record for this assembly. Readings are the tester's own measurements and the result is the tester's own determination.

This assembly passed after repair. The readings before and after the repair are both recorded below.

ASSEMBLY	
Assembly	BF-01 · Domestic service RP
Assembly type	Reduced pressure (RP)
Protects	Domestic
Size	2"
Manufacturer / model / serial	Demo · DEMO-RP · EXAMPLE-101
Location	Mechanical room
Hazard	High
Orientation	Horizontal
Water supplier	WaterOne (Johnson County, KS)
Meter number	EXAMPLE-M1
Notification number	EXAMPLE-2201
Supply pressure	68 psi

TEST

Initial test

2026-09-21 09:10 (America/Chicago)

MEASUREMENT	RESULT	VALUE	NOTE
Check valve #1 closed tight	OK	6.2 psid	—
Check valve #2 closed tight	Failed	0.4 psid	Debris on the seat
Relief valve opened	OK	2.8 psid	—
No. 2 shutoff valve held tight	OK	—	—

Repairs

COMPONENT	ACTION	NOTE	PARTS
Check valve #2	Rubber kit	Cleaned the seat and replaced the disc.	2" RP rubber kit × 1

Final test after repair

2026-09-21 09:55 (America/Chicago)

MEASUREMENT	RESULT	VALUE	NOTE
Check valve #1 closed tight	OK	6.1 psid	—
Check valve #2 closed tight	OK	1.9 psid	—
Relief valve opened	OK	2.9 psid	—
No. 2 shutoff valve held tight	OK	—	—

Passed

TESTER AND EQUIPMENT

Tester	Example plumber
Certification number	EXAMPLE-T-01
Company	Example Plumbing
Phone	(816) 555-0100
Test kit serial	EXAMPLE-KIT-7
Calibration	Calibrated 2026-06-02
Next test due	2027-09-21

RECORD HISTORY

Record ID	EXAMPLE-0003
Entered by	Example plumber
Saved at (UTC)	2026-09-21T16:20:00.000Z
Assembly revision at time of test	2

This is the servicing company's own record of the test. It is not a certificate and does not show that results were filed with the water supplier — that is issued and submitted separately, on the supplier's own form. Readings and the pass/fail result are the tester's observations and are not checked here against any state or utility threshold.